



ΚΡΟΥΝΟΙ ΟΡΕΙΧΑΛΚΙΝΟΙ ΜΕ ΠΙΤΑΛΟΥΔΑ

technique request -

- 1 ,all the seal component should be smear oil .
- 2 ,turn the stem,it should be freely and smooth , correct angle .
- 3 ,test under pressure 0.8MPa keep 6 seconds, guarantee without any leakage for 8 hours .
4. the normal work pressour<1.6MPa, normal temperature <120,

8	M4 bolt	1	Fe (zinc plated)			: 7mm
7	handle	1	aluminium			print red lacquer
6	O-ring	2	NBR	300011		ø26x16xrigidity 70+
5	stem	1	HPb59-1	2551013		brass
4	cap	1	HPb59-1	200052		plated nickel
3	ball	1	HPb59-1	200720		plated chrome
2	seat	2	PTFE	300132		ø26xø19x3
1	body	1	HPb59-1	155012		plated nickel
NO.	description	quantity	material	code	weight	remark



1/2" - 1" BALL VALVE

KF-A033