



3179B








7576

7577V





These adapters are designed with minimal flow restriction and recommended for use on the outlet of the LP-Gas delivery truck filler hose. If the controlled bleed off of the connection indicates the filler valve on the tank being filled has failed to close, the hose adapter should be left in place on the filler valve and disconnection should be made at the regular filler hose coupling. (Repair of the filler valve must be made as soon as possible). An integral check valve in these adapters helps prevent further loss of product. The standard filler valve cap should be attached to these adapters when left on the container.

Ordering Information

Part Number	Built-in Vent Valve	A Filler Valve Connection	B Hose Connection
7577V	Yes		
3179B	No	13/4" F. ACME	1¾" M. ACME
7576	Yes		



CHRYSSAFIDIS S.A

ATHENS: 3 AGRINIOU STR, TAVROS - (+30) 210 4836315-20

THESSALONIKI: DA12A STR, OT32, BIPE SINDOU

(+30) 2310 754681-4 / www.chryssafidis.com / sales@chryssafidis.gr

